

Parameter	Units	Health Guideline*	Aesthetic Guideline*	Average Value	# Health Compliance
Sulphate	mg/L	NG	≤ 250	52.4	NA
Total Dissolved Solids	mg/L	NG	≤ 600	518	NA
Trihalomethanes	µg/L	≤ 250	NG	156	84.6%
Turbidity	NTU	NG	≤ 5	0.1	NA
Zinc	mg/L	NG	≤ 3	0.009	NA
Hardness - International	ppm or mg/L	NG	NG	73	NG
Hardness - English Degrees	°e	NG	NG	5.11	NG
Hardness - French Degrees	°f	NG	NG	7.3	NG
Hardness - German Degrees	°dH	NG	NG	4.09	NG

* Australian Drinking Water Guidelines - 2011.

NA - Not Applicable
NG - No Guideline Value

^ Chlorinated systems use Free Chlorine as a measure and Chloraminated systems use Total Chlorine as a measure.
Although we aim for 100% compliance, the ADWG recognises that occasional exceedences may occur. Where there are sufficient sample results from a 12 month period, the 95th percentile statistic should be used to determine performance against the guideline value. Any exceedence requires immediate investigation and corrective action as agreed with SA Health.
Disclaimer: While every effort has been made to ensure the accuracy of the above data, SA Water accepts no liability for and gives no undertakings, guarantees or warranties concerning the use of the data for any purpose.

Service & Information

Residential

Business

Building & Developing

In Your Community

About Us

mySAWater

Follow Us On



Contact Us

Careers